



COUNTY OF PRINCE WILLIAM
5 County Complex Court, Prince William, Virginia 22192-9201
(703) 792-6930 Metro (703) 631-1703 FAX: (703) 792-7054

DEVELOPMENT SERVICES
DEPARTMENT
Division of
Building Development

Wade Hugh
Director

Product Approval 06-03
October 1, 2010

Division: 06	Wood And Plastics	Section 06090:	Wood and Plastic Fastenings
Product:	Simpson Strong-Tie (MASA and MASAP) Cast-In-Place Foundation Anchor Straps	Manufacturer:	Simpson Strong-Tie Company, Inc. 5956 West Las Positas Boulevard Pleasanton, California 94588
Report:	<u>ES Report No. ESR-2555</u>		

Conditions of Use:

This report is limited to the applications and products as stated in the ES Report ESR-2555 (attached). The ICC-ES Subcommittee on National Codes intends that the report be used by the Code Official to determine that it complies with the code requirements specifically addressed, provided that this product is installed in accordance with the conditions specified in 2555.

The Simpson Strong-Tie MASA and MASAP cast-in-place foundation anchor straps are used to connect wood foundation plates (sole plates), having a 2-inch or 3-inch nominal thickness, to concrete foundations or foundation walls in accordance with the referenced Sections of the IBC 2006, 2009 and IRC 2006, 2009.


Eric M. Mays, P.E., C.B.O.
Building Official

Attachment:

[ES Report No ESR-2555](#)
{ www.pwcgov.org/government/dept/development/bd/Documents/12974.pdf }

Cc: Product Approval Folder
Building Plan Review Branch
Construction Inspections Branch